

Information requirements for heat pump space heaters and heat pump combination heaters- 813/2013

Model: Samsung AE050JXYDEH & Joule 200L H.G Cyclone
Air-to-water heat pump: Yes
Water-to-water heat pump: No
Brine-to-water heat pump: No
Low-temperature heat pump: Yes
Equipped with a supplementary heater: Yes
Heat Pump combination heater: Yes
Parameters are declared for: low-temperature application
Parameters are declared for: average climate conditions



Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output	<i>Prated</i>	5	kW	Seasonal space heating energy efficiency	η_s	180	%
Declared capacity for heating for part load at indoor temperature 20°C and outdoor temperature T_j				Declared coefficient of performance for part load at indoor temperature 20°C and outdoor temperature T_j			
$T_j = -7^\circ\text{C}$	<i>Pdh</i>	4.40	kW	$T_j = -7^\circ\text{C}$	<i>COPd</i>	2.90	-
$T_j = +2^\circ\text{C}$	<i>Pdh</i>	2.70	kW	$T_j = +2^\circ\text{C}$	<i>COPd</i>	4.41	-
$T_j = +7^\circ\text{C}$	<i>Pdh</i>	2.20	kW	$T_j = +7^\circ\text{C}$	<i>COPd</i>	6.24	-
$T_j = +12^\circ\text{C}$	<i>Pdh</i>	2.20	kW	$T_j = +12^\circ\text{C}$	<i>COPd</i>	6.65	-
$T_j = \text{operation limit temperature}$	<i>Pdh</i>	5.00	kW	$T_j = \text{operation limit temperature}$	<i>COPd</i>	2.68	-
Bivalent temperature	<i>Tbiv</i>	-10.00	°C	Operation limit temperature	<i>TOL</i>	-10	°C
Degradation co-efficient	<i>Cdh</i>	0.9	-	Heating water operating limit temperature	<i>WTOL</i>	55	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	<i>P_{OFF}</i>	0.08	kW	Rated heat output	<i>P_{sup}</i>	3	kW
Thermostat-off mode	<i>P_{TO}</i>	0.011	kW	Type of energy Input	Electricity		
Standby mode	<i>P_{SB}</i>	0.011	kW	Outdoor sound power level	<i>L_{WA}</i>	61	dB
Crankcase heater mode	<i>P_{CK}</i>	0	kW				
Other items							
Capacity control		Variable					

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	128	%
Standby cylinder heat loss		2.064	kWh	Reference hot water temperature		50.85	°C
				DHW volume accounted for in test		200	L

Contact details	Joule IE, Kylemore Park West, Ballyfermot, Dublin 10.
-----------------	-------------------------------------------------------